# Optimal Kernel Parameters of Smooth-Windowed Wigner-Ville Distribution for Power Quality Analysis

A.R. Abdullah<sup>\*1</sup>, N.H.T.H.Ahmad<sup>2</sup>, A.Z.Shameri<sup>3</sup>, N.A Abidullah<sup>4</sup>, M.H. Jopri<sup>5</sup>, E.F.Shair<sup>6</sup>

<sup>1, 2, 4, 6</sup>Faculty of Electrical Engineering, Universiti Teknikal Malaysia Melaka, 76100 Durian Tunggal, Malaysia

<sup>3</sup>Faculty of Electrical Engineering Universiti Teknologi Malaysia, 81310 Skudai, Malaysia

<sup>5</sup>Faculty of Engineering Technology, Universiti Teknikal Malaysia Melaka, 75450 Ayer Keroh, Malaysia

<sup>\*1</sup>abdulr@utem.edu.my; <sup>2</sup>fizah\_jaa@yahoo.com; <sup>3</sup>zuri@fke.utm.my; <sup>4</sup>athira\_abidullah@yahoo.com; <sup>5</sup>hatta@utem.edu.my; <sup>6</sup>ezreen@utem.edu.my

*Abstract-* Bilinear time-frequency distributions (TFDs) are developed to represent time-varying signal jointly in time frequency representation (TFR). The TFDs offer a good time and frequency resolution, are appropriate to analyze power quality signals that consist of magnitude variation and multiple frequencies. However, the TFD suffers from cross-terms interferences because of their bilinear structures. In this paper, smooth-windowed Wigner-Ville distribution (SWWVD) is used to analyze power quality signals. The power quality signals are swell, sag, interruption, harmonic, interharmonic and transient. To get an accurate TFR, the parameters of the separable kernel are estimated from the signal. A set of performance measures are defined and used to compare the TFR for various kernel parameters. The comparison shows the signals with different parameters require different kernel settings in order to get the optimal TFR.

Keywords- Time-frequency Analysis; Power Quality; Bilinear Transformation

## I. INTRODUCTION

The power quality issue has become major concern for electric utilities and user .It's due to the growth of the electronic equipment used in industrial, commercial and domestic sector for example increasing used of solid state switching devices, nonlinear and power electronic switched, lighting control, computer and data processing [1-4].The main problem in industries is facing the distortion in electric supply. The low power quality can affect the lifetimes of loads, damaged, malfunction, instability, interruption and also affect the performance and economy. Thus, an automated monitoring system which is capable to estimate the presence of disturbance, accurately classify and also, characterize the disturbances is needed in order to improve the quality of signal and rectify the failure [3-5].

Time-frequency distributions (TFDs) are widely used to analyze power quality signal which represents the signal in jointly time-frequency representation (TFR) [3]. Previously, a popular method of linear TFD is short time Fourier transform (STFT). It uses a fixed analysis window [4] but has a major disadvantage that there is a compromise between time and frequency resolution. Alternatively, Wigner-Ville distribution, a bilinear TFD is a possible solution. It offers good time and frequency resolution but suffers from the presence of cross-terms interferences [4]. This inhibits interpretation of its TFR, especially when the signal has multiple frequency components.

This paper focuses on application of the smooth-windowed Wigner-Ville distribution (SWWVD) to analyze power quality signals. The power quality signals are swell, sag, interruption, harmonic, interharmonic and transient. This TFD consists of a separable kernel whose parameters are estimated from the time-lag signal characteristics. From the appropriate choice of the kernel parameters, the auto-terms are preserved and the cross-terms removed. A set of performance measures are defined based on the main-lobe width (MLW), peak-to-side lobe ratio (PSLR), signal-to-cross-terms ratio (SCR) and absolute percentage error (APE) to quantify the accuracy of the resulting TFR.

## II. SIGNAL MODEL

Power quality signals are divided into three classes: voltage variation for swell, sag and interruption signal, waveform distortion for harmonic and interharmonic signal, and transient signal. Signal models of the voltage variation, waveform distortion and transient signal are formed based on IEEE Std. 1159-1995 [5] and can be defined as

$$z_{vv}(t) = e^{j2\pi f_1 t} \sum_{k=1}^3 A_k \Pi_k (t - t_{k-1})$$
<sup>(1)</sup>

$$z_{wd}(t) = e^{j2\pi f_1 t} + A e^{j2\pi f_2 t}$$
<sup>(2)</sup>

$$z_{trans}(t) = e^{j2\pi f_1 t} \sum_{k=1}^{3} \prod_{k} (t - t_{k-1})$$

$$+ A e^{-1.25(t-t_1)/t_d} e^{j2\pi f_2(t-t_1)} \prod_{2} (t - t_1)$$

$$\prod_{k} (t) = 1 \quad \text{for } 0 \le t \le t_k - t_{k-1}$$
(4)

where k is the signal component sequence,  $A_k$  is the signal component amplitude,  $f_1$  and  $f_2$  are the signal frequency, t is the time and  $\Pi(t)$  is a box function of the signal.

In this analysis,  $f_1$ ,  $t_0$ ,  $t_1$  and  $t_3$  are set at 50 Hz, 0 ms, 100 ms and 200 ms and other parameters are defined as below:

- 1. Swell:  $A_1 = A_3 = 1$ ,  $A_2 = 1.2$ ,  $t_2 = 140$  ms
- 2. Sag:  $A_1 = A_3 = 1$ ,  $A_2 = 0.8$ ,  $t_2 = 140$  ms
- 3. Interruption:  $A_1 = A_3 = 1$ ,  $A_2 = 0$ ,  $t_2 = 140$  ms
- 4. Harmonic:  $A = 0.25, f_2 = 250$  Hz
- 5. Interharmonic:  $A = 0.25, f_2 = 275 \text{ Hz}$
- 6. Transient: A = 0.5,  $f_2 = 1000$  Hz,  $t_d = 15$  ms,  $t_2 = 115$  ms

# III. SMOOTH-WINDOWED WIGNER-VILLE DISTRIBUTION

The smooth-windowed Wigner-Ville distribution (SWWVD) [6] can be expressed as

$$\rho_{z,swwvd}(t,f) = \int_{-\infty}^{\infty} H(t) * K_z(t,\tau) w(\tau) e^{-j2\pi f\tau} d\tau$$
(5)

where H(t) is the time-smooth (TS) function,  $w(\tau)$  is the lag-window function.  $K_z(t,\tau)$  is the bilinear product of the signal of interest, z(t), and is further defined as

$$K_{z}(t,\tau) = z(t+\tau/2)z^{*}(t-\tau/2)$$
(6)

In this paper, Hamming window is used as the lag-window and raised-cosine pulse as the TS function [6]. It defined as

$$w(\tau) = 0.54 + 0.64 \cos \frac{\pi \tau}{T_g}, \quad |\tau| \le T_g$$
 (7)

$$H(t) = 1 + \cos(\pi t / T_{sm}) \qquad 0 \le t \le T_{sm}$$
  
= 0 elsewhere (8)

The Doppler representation of this TS function obtained from the Fourier transform with respect to time is

$$h(v) = \frac{\sin(\pi v T_{sm})}{\pi v T_{sm}} + \frac{1}{2} \frac{\sin(\pi (v - 1/2T_{sm}))}{\pi (v - 1/2T_{sm})} + \frac{1}{2} \frac{\sin(\pi (v + 1/2T_{sm}))}{\pi (v + 1/2T_{sm})}$$
(9)

It is a low-pass filter in the Doppler domain where the cutoff Doppler frequency is

$$\nu_c = 3/2T_{sm} \tag{10}$$

## IV. TIME-LAG SIGNAL CHARACTERISTIC

The bilinear product in (6) is represented in time-lag representation which is used to determine the separable kernel parameters of the SWWVD. Generally, the time-lag representation can be defined in terms of auto-terms and cross-terms as

$$K_{z}(t,\tau) = K_{z,auto}(t,\tau) + K_{z,cross}(t,\tau)$$
<sup>(11)</sup>

Voltage variation signal has a variation in the root mean square (RMS) value from nominal voltage [5]. The auto-terms and cross-terms for the signal in (1) are expressed as

$$K_{autavv}(t,\tau) = \sum_{k=1}^{3} A_{k}^{2} e^{j2\pi f_{1}\tau} K_{\Pi_{k,k}}(t,\tau)$$
(12)

$$K_{crossvv}(t,\tau) = \sum_{\substack{k=1\\k\neq l}}^{3} \sum_{l=1}^{3} A_k A_l e^{j2\pi f_l \tau} K_{\Pi_{k,l}}(t,\tau)$$
(13)

where k and l represent the signal component,  $A_k$  and  $A_l$  are the signal components amplitude and the bilinear product of the box function,  $\Pi(t)$ , is defined as

$$K_{\Pi_{k,l}}(t,\tau) = \Pi_k (t + \tau/2 - t_k) \Pi_l (t - \tau/2 - t_l)$$
(14)

Equations (12) and (13) show that the auto-terms lie along the time axis and are centered at  $\tau = 0$ , while the cross-terms are elsewhere. Fig. 1 shows the time-lag signal representation and the auto-terms are highlighted in green while the cross-terms are densely dotted. Thus, to preserve the auto-terms and suppress the cross-terms, the lag-window in (7) should cover all the auto-terms while removing the cross-terms as much as possible. The lag-window width can be set as

$$\left|T_g\right| \le t_2 - t_1 \tag{15}$$

Since the cross-terms do not have Doppler-frequency terms as shown in (13), the TS function used in (8) is an impulse function. Therefore, only a lag-window is required and the resulting is known as the windowed Wigner-Ville distribution (WWVD).



Fig. 1 Bilinear product of the voltage variation

Waveform distortion signal is a steady state signal which consists of multiple frequency components [7]. The auto-terms and cross-terms of the signal in (2) are defined as

$$K_{autazwd}(t,\tau) = e^{j2\pi f_1 \tau} + A^2 e^{j2\pi f_2 \tau}$$
(16)

$$K_{cross,zwd}(t,\tau) = 2Ae^{j2\pi \left(\frac{f_2+f_1}{2}\right)^{\tau}} \cos(2\pi (f_2-f_1)t)$$
(17)

As shown in (17), the cross-terms have a Doppler-frequency component at  $\upsilon = (f_2 - f_1)$ . To remove the cross-terms, the TS function is used with the Doppler cutoff frequency set as  $\upsilon_c \le |f_2 - f_1|$ . Thus, the TS function parameter,  $T_{sm}$ , can be set as

$$T_{sm} \ge \frac{3}{2|f_2 - f_1|} \tag{18}$$

In addition, the lag-window is also used to obtain desirable lag-frequency resolution in the TFR. By choosing the lagfrequency resolution less or equal to  $f_1/2$ , the resulting TFR is able to differentiate harmonic and interharmonic frequency components. Higher lag-frequency resolution can be obtained with higher  $T_g$  but it results in increased computation complexity and memory size to calculate the TFR.

Transient signal is a sudden signal which changes in steady state condition at non-fundamental frequency [5]. From the signal model in (3), the auto-terms and cross-terms are expressed as

$$K_{autotrans}(t,\tau) = \sum_{k=1}^{3} e^{j2\pi f_{1}\tau} K_{\Pi_{k,k}}(t,\tau) + A^{2} e^{-2.5(t-t_{1})} e^{j2\pi f_{2}\tau} K_{\Pi_{2,2}}(t,\tau)$$
(19)

$$K_{transcross}(t,\tau) = \sum_{\substack{k=1\\k\neq l}}^{3} \sum_{l=1}^{3} e^{j2\pi f_{1}\tau} K_{\Pi_{k,l}}(t,\tau) + A e^{-1.25(t+\tau/2-t_{1})}$$

$$\left(\sum_{l=1}^{3} e^{j2\pi (f_{2}-f_{1})t-f_{2}t_{1}} e^{j2\pi (f_{2}+f_{1})\tau/2} K_{\Pi_{2,l}}(t,\tau) + \sum_{k=1}^{3} e^{-j2\pi (f_{2}-f_{1})t-f_{2}t_{1}} e^{j2\pi (f_{2}+f_{1})\tau/2} K_{\Pi_{k,2}}(t,\tau)\right)$$

$$(20)$$

The locations of the auto-terms in (19) and the cross-terms in (20) are shown in Fig. 2. Similar to the voltage variation signal, the lag-window width is set at  $|T_g| \le (t_2 - t_1)$  to remove the cross-terms located away from the time axis and to preserve the auto-terms lying along the time axis. For this signal, the TS function is needed to remove the remaining cross-terms that have Doppler-frequency component. The cutoff Doppler-frequency of the TS function is set at  $\upsilon_c \le |f_2 - f_1|$  by setting  $T_{sm}$  as in (18).



Fig. 2 Bilinear product of the transient signal

#### V. PERFORMANCE MEASUREMENT

In this paper, the power quality signals are analyzed using SWWVD with various kernel parameters. The performance of TFR is compared in terms of main-lobe width (MLW), peak-to-side lobe ratio (PSLR), signal-to-cross-terms ratio (SCR) and absolute percentage error (APE). These measurements are adopted to evaluate the performance of the TFD in terms of its concentration, accuracy, resolution, and interference minimization [6].

MLW and PSLR are from the power spectrum which is derived from the frequency marginal of the TFR [6] as shown in Fig. 3. MLW is the width at 3dB below the peak of the power spectrum, while PSLR is the power ratio between the peak and the highest side-lobe calculated in dB. Low MLW indicates good frequency resolution that gives the ability to resolve closely-spaced sinusoids. PSLR should be as high as possible to resolve signal of various magnitudes.



Fig. 3 Performance measures used in the analysis

SCR is a ratio of signal to cross-terms power in dB. High SCR indicates high cross-terms suppression in the TFR. It can be calculated by

 $SCR = 10 \log(\text{signal power/cross} - \text{terms power})$  (21)

Besides the MLW, PSLR and SCR, APE is also applied to quantify the accuracy of the signal measurement. Details on this performance measure are discussed in [8] and can be expressed as

$$APE = \frac{x_i - x_m}{x_i} \times 100\%$$
<sup>(22)</sup>

where  $x_i$  is actual value and  $x_m$  is measured value. Low APE shows high accuracy of the TFR. In general, an optimal kernel of TFD should have low MLW and APE while high PSLR and SCR.

# VI. RESULTS

The best kernel parameters for the voltage variation signal are at  $T_g = 10$  ms and  $T_{sm} = 0$  ms. A bigger  $T_g$  will results in more cross-terms while higher  $T_{sm}$  is not necessary because the signal has no Doppler-frequency component. For the waveform distortion signal, the optimal  $T_g$  is 40ms, sufficient to differentiate between harmonic and interharmonic signals. The  $T_{sm}$  for harmonic and interharmonic depends on frequency difference in the signal components. From the signal model described in Section II, the optimal  $T_{sm}$  for harmonic and interharmonic signals are 7.5 and 6.67 ms. The best parameters for transient signal are  $T_g = 10$  ms and  $T_{sm} = 1.578$  ms because the transient duration is 15 ms and Doppler-frequency estimated from the time-lag representation is 525 Hz. The performance of SWWVD for various kernel parameters is shown in Table I.

Fig. 4 shows the example of TFRs for the swell, transient and harmonic signals.

TABLE 1 PERFORMANCE COMPARISON OF SWWVD WITH VARIOUS KERNEL PARAMETER

Kernel	Performance measures	Voltage variation			Waveform distortion		Transient
Parameters		Swell	Sag	Interruption	Harmonic	Interharmonic	Tansient
$T_g=10 \mathrm{ms}$ $T_{sm}=0 \mathrm{ms}$	MLW (Hz)	25	25	25	25	25	25
	PSLR (dB)	614.82	614.82	614.82	623.12	50.795	19.102
	SCR (dB)	15.641	17.799	55.446	4.4785	4.57578	13.764
	APE (%)	0.2083	0.625	0.625	0.3755	100	55
$T_s = 10 \text{ms}$ $T_{sm} = 1.578 \text{ms}$	MLW (Hz)	25	25	25	25	25	25
	PSLR (dB)	218.09	216.68	198.78	18.835	49.889	86.259
	SCR (dB)	13.491	15.038	35.107	5.6064	5.7679	14.171
	APE (%)	3.125	12.708	100	55.544	100	1.6667
$T_g = 40 \mathrm{ms}$ $T_{sm} = 6.67 \mathrm{ms}$	MLW (Hz)	6.25	6.25	6.25	6.25	6.25	6.25
	PSLR (dB)	120.03	100.92	81.315	51.168	655.78	129.74
	SCR (dB)	6.7221	8.4121	28.701	28.570	24.256	7.7198
	APE (%)	20.416	35.417	100	20.142	0.125	90.556
$T_g = 40 \mathrm{ms}$ $T_{sm} = 7.5 \mathrm{ms}$	MLW (Hz)	6.25	6.25	6.25	6.25	6.25	6.25
	PSLR (dB)	122.91	102.56	111.22	664.29	651.32	131.79
	SCR (dB)	6.6568	8.3551	28.600	41.739	32.356	7.4996
	APE (%)	21.458	36.667	100	0.18930	0.125	97.778



Fig. 4 The TFRs of power quality signals



Fig. 5 Performance of TFR using SWWVD with various kernel parameter for transient signal.

In the contour plots, the red color represents the highest power while the blue color represents the lowest power.

Fig. 4a shows that the swell signal occurs between 100 and 140 ms while its frequency is 50 Hz. For the transient signal, its duration is between 100 and 115 ms and its frequency is 1000 Hz as shown in Fig. 4b.Meanwhile for the harmonic signal in Fig. 4c it consists three frequency component which is 50Hz, 350 Hz and 1000 Hz.Thus, the true characteristics of the signal is represent in TFR.

Fig. 5 shows the performance measure for transient signal at. optimal  $T_{sm}$  with various  $T_g$  and optimal  $T_g$  with various  $T_{sm}$ . The optimal kernel parameter for transient signal is obtained from Table 1 which is  $T_g = 10$  ms and  $T_{sm} = 1.578$ ms. Fig. 5a shows that at optimal  $T_{sm}$  and when  $T_g$  is set higher, the MLW is smaller indicating a higher frequency resolution of the TFR However, it suffers from the reduction of the cross-terms suppression which results in smaller. This because higher  $T_g$  covers more adjacent cross-terms in lag-axis in the bilinear product. As a result, the APE is higher which presents lower accuracy of the signal characteristic measurement.

Fig. 5b shows the optimal  $T_g$  and when  $T_{sm}$  is set higher than its optimal value, the SCR increases while the MLW remains constant. It indicates that higher  $T_{sm}$  improves the cross-terms suppression and does not give any effect to the frequency resolution. However, the APE is also higher, which shows that the time resolution of the TFR is lower. This is because the application of TS function with higher  $T_{sm}$  increases the smearing of the auto-terms in time domain. Thus, there is a compromise between cross-terms suppression and time resolution to obtain optimal TFR.

### VII. CONCLUSIONS

The TFR for power quality signals can be obtained using the SWWVD. For optimal TFR, the kernel parameters can be determined mathematically from the signal characteristics in time-lag representation with the objective to remove cross-terms and preserve auto-terms in the bilinear product. A set of performance measures were defined to compare the TFRs.

For voltage variation signal, only the  $T_g$  is adjusted to obtain accurate TFR while the waveform distortion and transient signals require the adjustment of both  $T_g$  and  $T_{sm}$ . From the TFR, the estimated signal parameters can be used to classify the power quality events signals.

## ACKNOWLEDGMENT

The authors would like to thank Universiti Teknikal Malaysia Melaka (UTeM) for its financial support from PJP grant (PJP/2011/FKE(34C)/S00976) for sponsoring the resources for this research.

## REFERENCES

- [1] A R Rahim Abdullah, A.Z. Sha'meri, N.A. Mohd Said, N. Mohd Saad, A. Jidin, "Bilinear Time-Frequency Analysis techniques for Power Quality Signals", *Proceedings of the International MultiConference of Engineers and Computer Scientists* 2012, IMECS 2012.
- [2] Likhitha. R, A. Mnajunath, E.Pratibha, "Development of Mathematical model for Various PQ Signals and Its Validation for Power Quality Analysis", *International Journal of Engineering Research and Development*, Volume 1, Issue 3 (June 2012), pp. 37-44.
- [3] A. R. Abdullah, A. Z. Sha'ameri and A. Jidin, "Classification of Power Quality Signals using Smooth-Windowed Wigner-Ville Distribution", *Proceedings of IEEE International Conference on Electrical Machines and System (ICEMS 2010)*, pp. 1981-1985, Incheon, Korea, Oct. 2010.
- [4] A. R. Abdullah and A. Z. Sha'ameri, "Power Quality Analysis using Smooth-Windowed Wigner-Ville Distribution", International Conference on Information Science, Signal Processing and their Applications (ISSPA 2010), pp. 798-801, 2010.
- [5] T. J. Lynn and A. Z. Sha'ameri, "Adaptive Optimal Kernel Smooth-Windowed Wigner-Ville Distribution for Digital Communication Signal", *EURASIP Journal on Advances in Signal Processing*, 2008.
- [6] S. Mishra, C. N. Bhende and B. K. Panigrahi, "Detection and Classification of Power Quality Disturbances Using S-Transform and Probabilistic Neural Network", *IEEE Trans. on Power Delivery*, Vol. 23, No. 1, pp. 280-287, Jan. 2008.
- [7] A. R. Abdullah and A. Z. Sha'ameri, "Power Quality Analysis using Linear Time-Frequency Distribution", *IEEE Int. Conf. on Power and Energy*, Dec. 2008.
- [8] B. R. Godoy, O. P. J. Pinto and L. Galotto, "Multiple Signal Processing Techniques Based Power Quality Disturbance Detection, Classification, and Diagnostic Software", *Int. Conf. on Electrical Power Quality and Utilisation*, pp. 1-6, Oct. 2007.
- [9] R. Tomas, M. Vaclav, M. J. Fernando, R. Pedro and A. C. Serra, "On-line Detection and Classification of Power Quality Disturbances in a Single-phase Power System", *Int. Conf. on Power Eng., Energy and Elec. Drives*, pp. 713-718, April 2007.
- [10] K. Poh and P. Marziliano, "Analysis of Neonatal EEG signals using Stockwell Transform", Int. Conf. on Eng. in Medicine and Biology Society, pp. 594-597, Aug. 2007.
- [11] A. Moreno, Power Quality: Mitigation Technologies in a Distributed Environment, Springer, 2007.
- [12] IEEE Recommended Practice for Monitoring Electrical Power Quality. IEEE Std. 1159-1995 Approved Jun. 14, 1995.



**A.R Abdullah** was born in Kedah, Malaysia in 1979. He received his B. Eng., Master, PhD Degree from University of Technology Malaysia in 2001, 2004 and 2011 in Electrical Engineering and Digital Signal Processing. He is currently a Senior Lecturer and Coordinator of Center of Excellent Robotic and Industrial Automation (CeRiA) in Universiti Teknikal Malaysia Melaka (UTeM).



**N.H.T.H** Ahmad was born in Terengganu Malaysia in 1986. She received diploma and B.Eng from Universiti Teknikal Malaysia Melaka in 2007 and 2010 respectively in Electrical Engineering and Control, Instrumentation and Automation. She is now continues her Master degree at same university in Digital Signal Processing.



**M.H Jopri** was born in Johor, Malaysia in 1979. He received his B.Sc from University of Technology Malaysia in 2004 and Msc. in Electrical Power Engineering from Rheinisch-Westfälische Technische Hochschule Aachen (RWTH), Germany in 2011. Since 2005, he has been an academia staff in the Universiti Teknikal Malaysia Melaka (UTeM). His fields of interests are power quality, motor drives and power electronics.